

**SPECIAL BIDS AND AWARDS COMMITTEE**
**SUPPLEMENTAL BID BULLETIN NO. 03**
**Construction of New Pier**  
**Invitation to Bid No. 2023-02-052**


The PNOC Special Bids and Awards Committee hereby adopts the following clarifications in the Philippine Bidding Documents:

	Queries	Response
1	Cathodic Protection and design life are not mentioned on the design drawing and specification, please confirm if it is needed or not.	Cathodic Protection is not required, piles are protected by polyurethane paints, 1500 microns (protegel).
2	Details of the tie rod and typical section of steel sheet pile CW-07-034. The clogged materials at the bottom of the pile did not specify the construction materials.	Clogged materials inside the tubular sheet piles can be determine on borehole logs.

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Document.

For guidance and information of all concerned.

Issued this 25<sup>th</sup> of May 2023.

  
**ATTY. RONALD C. CHUA**  
 Chairperson